

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Ranjit Ray, Junior Engineer (PH)

(Name of Officers with designation) from PHED

inspected the Parents' Pride Public School, Bhaktisalгада, Nabarangpur

(Name & Address of the school) on (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. dated

of EE RWS&S Nabarangpur (PHED Lab) certified that the

Parents' Pride Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 09.2.25

Signature with Seal: [Signature] 09/02/25

Name

Designation

Name & Address of the Office / Department : PH Section, NGR

To Parents' Pride public School
Bhaktisalгада, Nabarangpur.
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

RURAL WATER SUPPLY & SANITATION DIVISION , NABARANGPUR
DISTRICT WATER TESTING LABORATORY , NABARANGPUR

Letter No.

286

Date.


7.2.24

TEST REPORT

ISSUED TO	PARENTS PRIDE PUBLIC SCHOOL, NABARANGPUR	DATE OF RECEIPT:	07.02.2024
		DATE OF TESTING :	08.02.2024
		SAMPLE COLLECTED BY :	PARTY
		SOURCE :	BOREWELL

SL NO	PARAMETERS	RESULTS	COMPELETE TEST AS PER -IS 10500-2012	
			ACCEPTABLE LIMIT	PERMISSIBLE LIMIT
1	Odour	Agreeble	Agreeble	Agreeble
2	pH	6.6	6.5-8.5	6.5-8.5
3	Taste	Agreeble	Agreeble	Agreeble
4	Conductivity moh/cm	22.95		
5	Turbidity as NTU	4.4	1	5
6	TDS mg/ltr	15	500	2000
7	Iron mg/ltr	0.684	0.3	1
8	Fluoride mg/ltr	0.28	1	1.5
9	Chloride mg/ltr	28	250	1000
10	Total Hardness mg/ltr	100	200	600
11	Total Alkalinity mg/ltr	64	200	600
12	E Coil, MPN /100ml	0	0	0

The sample is under permissible limit to the above parameters only.
It is Portable for use


Laboratory Chemist
RWS&S Division, Nabarangpur
R. W. S. & S. Division
Nabarangpur.


Executive Engineer
RWS&S Division , Nabarangpur